

**Issued by** NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 9 of Directive 2004/22/EC, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2004/22/EC, to:

**Manufacturer** Itron  
Langer Road, Felixstowe  
Suffolk IP11 2ER  
England

**Measuring instrument** A static **Active Electrical Energy Meter**

Type : ACE2000 type 400

Reference voltage : 230 V

Reference current : 5 A

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes  
– Description T10314 revision 0  
– Documentation folder T10314-1

**Valid until** 11 October 2020

**Issuing Authority** **NMI Certin B.V., Notified Body number 0122**  
11 October 2010

  
C. Oosterman  
Head Certification Board

**NMI Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
applicant shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge  
objection against this decision,  
within six weeks after the date of  
submission, to the general manager  
of NMI (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete  
document only is permitted.