

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Elster GmbH Steinernstrasse 19–21 D-55252 Mainz-Kastel Germany
Measuring instrument	A Turbine Gas Meter Type : SM-RI-X Destined for the measurement of : Gas volume Accuracy class : Class 1,0 Environment classes : M1 / E2 Temperature range : -25 °C / +70 °C Further properties are described in the annexes: – Description T11210 revision 0; – Documentation folder T11210-1.
Valid until	22 December 2027

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
22 December 2017



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin BV.as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.