

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity assessment procedure mentioned in article 17 of Directive
2014/32/EU, after having established that the Measuring instrument meets
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Cavagna Group S.p.A. Divisione RECA
Via Statale 11/13
25011 Ponte S.Marco di Calcinato (Bs)
Italy

Measuring instrument **A Rotary Displacement Gas Meter**
Type : FMR
FMR-Dual
Manufacturer's mark or name : MESURA and/or Cavagna Group
Destined for the measurement of : Gas volume
Accuracy class : Class 1,0
Environment classes : M1 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T12185 revision 1;
- Documentation folder T12185-2.

Valid until 1 June 2031

Remarks This revision replaces the earlier version(s), including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
3 December 2021

Certification Board

NMI Certin B.V.
Thijssseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.