

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity assessment procedures mentioned in article 17 of Directive  
2014/32/EU, after having established that the measuring instrument meets  
the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Flonidan A/S  
Islandsvej 29  
8700 Horsens  
Denmark

Measuring instrument **Ultrasonic gas meter**

Type	: SciFlo X G4UDZV-2
Manufacturer's mark or name	: Flonidan A/S
Destined for the measurement of	: Gas volume of natural gas, type H, L and E
Accuracy class	: Class 1,5
Environment classes	: M1 / E2
Temperature range	: -10 °C / +55 °C
Designed for	: Condensing humidity
Location	: Closed

Further properties are described in the annexes:  
– Description T12655 revision 0;  
– Documentation folder T12655-1.

Valid until 25 January 2034

Initially issued 25 January 2024

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
25 January 2024

## Certification Board

**NMI Certin B.V.**  
Thijssseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
[certin@nmi.nl](mailto:certin@nmi.nl)  
[www.nmi.nl](http://www.nmi.nl)

This document is issued under the provision that  
no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMI Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/growth/tools-databases/nando/](http://ec.europa.eu/growth/tools-databases/nando/)

Reproduction of the complete  
document only is permitted.

This document is digitally signed  
and sealed. The digital signature  
can be verified in the blue ribbon at  
the top of the electronic version of  
this certificate.