

EU-type examination certificate

Number **T10451** revision 3
Project number 3820707
Page 1 of 1

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Dandong Gas Meter Co., Ltd.
No. 66 Gucheng Road, Yuanbao District, Dandong City,
Liaoning Province,
People's Republic of China

Measuring instrument **Diaphragm gas meter**

Type : J1.6CII
J2.5CII

Destined for the measurement of : Gas volume
Accuracy class : Class 1,5
Environment classes : M2 / E1
Temperature range : -25 °C / +55 °C
Location : Closed

Further properties are described in the annexes
– Description T10451 revision 3
– Documentation folder T10451-3

Valid until 19 June 2024

Initially issued 19 June 2014

Remarks This revision replaces the earlier version(s), except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
5 June 2024

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.