

CERTIFICATE

EC-Type examination certificate

Authorised representative : Inepro Metering BV
Contact person : Mr. D. van der Vaart
Address : P.O. Box 92, 2450 AB Leimuiden
Country : Netherlands

Manufacturer : Zhejiang Dengli Electric Meter Co., Ltd.
Address : Xirendang Industrial Zone, Liushi Town, Yueqing City, Zhejiang Province
Country : China

Instrument : Electronic single-phase two-wire energy meter
Direct connected

Type : ADM1TE
Register : Mechanical
Accuracy Class : B
Measurement range : 230 V
0,25..5 (32)A
50 Hz
2000 imp./kWh

Temperature range : -10..40 °C
Use : Indoor
Environment class : M1 / E2

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)

EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : January 7, 2018

The results are recorded in the following annex: test report 2107547-QUA/CAL 07-4040

KEMA Quality B.V.
Arnhem, January 7, 2008



ing. J.H.M. Overbeek
Certification manager
Notified body number 0344



ir. P.J.J.G. Nabuurs
Managing Director
Certificate nr. 2107547-QUA/CAL 07-4040EC

Integral publication of this certificate and adjoining reports is allowed.