KEMA Labs

EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1011-20
Manufacturer Address Postal code, City Country	ZIV Aplicaciones y Tecnología S.L. Parque Tecnológico, 210 48170 Zamudio Spain
Production site	ZIV Aplicaciones y Tecnología S.L.
Address	Parque Tecnológico, 210
Postal code, City	48170 Zamudio
Country	Spain
Instrument	Electronic single-phase two-wire energy meter
	Direct connected
Mark - Type	5CTA1DCE000AAD0
Register	LCD
Accuracy Class	Active: 2/A
Measurement range	230 V a CESI brand
	5(80) A
	50 Hz
Temperature range	-25°C70°C
Use	Indoor
Protection Class	
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy is
	added in separate registers
	\checkmark \cdot 1927 \cdot $/$ \uparrow $/$

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).

Certification was based on compliance with the following harmonised standards:		
EN 50470-1:2006	Electricity metering equipment (a.c.)-part 1: General requirements, tests and	
	test conditions - Metering equipment (class indexes A, B and C)	
EN 50470-3:2006	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static	

EN 50470-3:2006	Electricity metering equipment (a.c.)-part 3: Partic
	meters for active energy (class indexes A, B and C)
Valid until	October 4, 2033

Based on a non-recurrent examination.

Revision 4 of this certificate. The results are recorded in the following annex: test report 1616-23 R0.

Issued by KEMA B.V.

Alessandro Bertani Director, Services & Smart Technologies





Arnhem, October 4, 2023

© KEMA Labs, a CESI brand

Please note that this document has been issued for information purposes only, and that the original bound and sealed paper copy of the Certificate including the results of the tests of the object will prevail. This document does not imply that KEMA Labs has certified or approved any object other than the specimen tested.