

# **EU-TYPE EXAMINATION CERTIFICATE**

Holley Technology Ltd. No.181 Wuchang Avenue, Yuhang District

310023 HANGZHOU

China

**EU-Type Examination** Certificate No. 1264-19

Revision 1



**Type** DDSY283SR

Electronic single-phase two-wire energy meter **Object** 

Direct connected

The object has been assessed and meets the requirements of

EU Directive 2014/32/EU

Module B

The energy meter(s) meet(s) the essential requirements of Annex V of EU Directive 2014/32/EU, on the harmonization of the laws of Member States relating to the making available on the market of measuring instruments (recast).

This Certification is based on the report(s) listed in the report list in this Certificate.

This Certificate is valid until: July 10, 2034. DIUA

This Certificate comprises 8 pages in total.

Issued by KEMA B.V. Klingelbeekseweg 195, Arnhem, The Netherlands Notified Body 2290

Alessandro Bertani

Director,

Services & Smart Technologies

Arnhem, July 10, 2024







# **REVISION OVERVIEW**

The edition with the highest revision number always replaces the earlier issued editions.

Rev. No.	Date of issue	Reason
0 (V1)	24 May 2019	First issue
1	July 10, 2024	Report 1236-24 added

### **REPORT LIST**

This Certificate is issued based on the following reports.

Report number	Revision	Firmware version
1234-19	V2	HMSP1626001G3P0000998B0190313112
1636-24	0	HMS16X26001G3P000096200231228301
1637-24	0	



# 1 TECHNICAL DATA

Manufacturer	Holley Technology Ltd.,					
	No.181 Wuchang Avenue, Yuhang District,					
	310023 HANGZHOU,					
	China					
Production location	Holley Technology Ltd.,					
	No.181 Wuchang Avenue, Yuhang District,					
	310023 HANGZHOU,					
_	China DDSY283SR					
Туре						
Connection	Direct					
Type of circuit	1P2W two-element 1P2W					
Accuracy class Wh	1/B					
Accuracy class varh	2					
Meter constant	1000 imp/kWh					
	1000 imp/kvarh					
V range	220 – 240 V	230 V				
I range I <sub>min</sub> -I <sub>n</sub> (I <sub>max</sub> )		0,25-5(100) A				
Frequency	50 Hz					
Temperature range	-40 80 °C					
Use	Indoor					
IP rating	IP54					
Protection Class	II					
Impulse voltage	6 kV					
Internal clock	ock Crystal controlled					
Environmental class	M1, M2, E1 and E2, CISPR32 class B					
LR Firmware ID	HMSP1626001G3P0000998B0190313112	HMS16X26001G3P000096200231228301				
LR Firmware CRC	-	0x01928E45				
Register	LCD					
Registry method(s):	d(s): Bi-directional method with separate registers: received- and delivered energy is added in separate registers.					

-3-




#### 2 PHOTOGRAPHS AND SEALING







#### 3 EXAMPLES OF NAME PLATES





### 4 CALCULATION OF THE COMPOSITE ERROR / MPE

During the type approval test the intrinsic errors for temperature, voltage and frequency variation are determined per load point. The composite error is determined with the following formula:

-6-

$$\varepsilon_m = \sqrt{\varepsilon^2(I,\cos\varphi) + \delta^2(T,I,\cos\varphi) + \delta^2(U,I,\cos\varphi) + \delta^2(f,I,\cos\varphi)}$$

Where

 $\varepsilon^2(I, cos\varphi)$  = Intrinsic error of the meter at a certain load

 $\delta^2(T, I, cos\varphi)$  = Additional error due to the variation of the temperature at the same load

 $\delta^2(U, I, cos\varphi)$  = Additional error due to the variation of the voltage at the same load

 $\delta^2(f, I, cos\varphi)$  = Additional error due to the variation of the frequency at the same load

Results are in the table below:

I in %	cos φ	Compos	Composite error %							
of I <sub>ref</sub>		-40 ºC	-25 ºC	-10 ºC	5 ºC	30 ºC	40 ºC	55 ºC	70 ºC	80 ºC
5	1	0,21%	0,18%	0,17%	0,20%	0,13%	0,13%	0,14%	0,21%	0,21%
10	1	0,17%	0,14%	0,12%	0,12%	0,11%	0,12%	0,16%	0,22%	0,19%
10	0,5 ind.	0,14%	0,12%	0,12%	0,09%	0,11%	0,10%	0,14%	0,17%	0,16%
10	0,8 cap.	0,21%	0,18%	0,16%	0,14%	0,12%	0,12%	0,16%	0,22%	0,19%
I <sub>max</sub>	1	0,11%	0,10%	0,10%	0,10%	0,09%	0,11%	0,13%	0,18%	0,18%
I <sub>max</sub>	0,5 ind.	0,08%	0,08%	0,08%	0,08%	0,08%	0,08%	0,11%	0,14%	0,13%
I <sub>max</sub>	0,8 cap.	0,11%	0,11%	0,11%	0,11%	0,11%	0,12%	0,14%	0,18%	0,20%





# **5 OPTIONS AND VARIANTS**

Overview of variants with details

Type designation	Details of the meter	
DDSY283SR	<ul> <li>Communication options:         optical port         RS485         Remote communication port</li> <li>Supply control switch</li> </ul>	



# **END OF DOCUMENT**

The laboratories of KEMA Labs are:

- CESI S.p.A., Milan, Italy, accredited by ACCREDIA in accordance with ISO/IEC 17025:2017 under no. 0030L.
- FGH Engineering & Test GmbH, Mannheim, Germany, accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018 under no. D-PL-12110-01-00.
- IPH Institut "Prüffeld für elektrische Hochleistungstechnik" GmbH, Berlin, Germany accredited by DAkkS in accordance with DIN EN ISO/IEC 17025:2018 under nos. D-PL-12107-01-00 and D-K-12107-01-00.
- KEMA B.V., Arnhem, The Netherlands, accredited by RvA in accordance with EN ISO/IEC 17025:2017 under nos. L020, L218 and K006 and with EN ISO/IEC 17065:2012 under no.
- KEMA Labs, Zkušebnictví, a.s., Prague, the Czech Republic, testing laboratory no. 1035 accredited by CAI in accordance with ČSN EN ISO/IEC 17025:2018.
- KEMA-Powertest, LLC, Chalfont, United States, accredited by A2LA in accordance with ISO/IEC 17025:2017 under no. 0553.01.

Tests are carried out under the scope of accreditation, unless otherwise indicated in the chapter 'Tests carried out'.









