



CERTIFICATE

TYPE TEST OF ENERGY METERS

Manufacturer : Inepro Metering B.V.
Contact person : D. van der Vaart
Address : Pondweg 7
Postal code, Place : 2153PK, Nieuw-Venep
Country : The Netherlands

Production site : Zhejiang Yongtailong Electronic Co., Ltd.
Address : No. 320 Tongsheng Road, Tongxiang
Postal code, Place : 314500, Jiaxing City, Zhejiang
Country : China

Instrument : Electronic single-phase two-wire energy meter
Direct connected

Mark - Type : MEMO4-M, MEMO4-M 2T, MEMO4-M Mb and MEMO4-M Mod
Register : LCD
Accuracy Class : 1 / B
Measurement range : 230 V
5(45) A
50 Hz
10000 imp./kWh

Use : Indoor
Protection Class : II
Registry method : Programmable

The energy meter meets the requirements of:


IEC 62052-11 (2003) : Electricity metering equipment (a.c.) - General requirements, tests and test conditions - Metering equipment

IEC 62053-21 (2003) : Electricity metering equipment (a.c.) - Static meters for active energy (classes 1 and 2)

Based on a non-recurrent examination.

The results are recorded in our test report with reference TIC 1070-14.

KEMA Nederland B.V.
Arnhem, 12 March 2015


ing. S.A.M. Verhoeven
Business Line Director Testing, Inspections & Certification
Certificate nr. TIC 1070-14