

EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1299-20
Manufacturer	Zhejiang Reallin Electron Co., Ltd.
Contact person	Qian Shaobo
Address	No.8 Shuangyang Rd, Jiulong Village, Renhe town, Yuhang district, Hangzhou City, Zhejiang Province
Postal code, City	311107, Hangzhou
Country	China
Production site	Zhejiang Reallin Electron Co., Ltd.
Address	No.8 Shuangyang Rd, Jiulong Village, Renhe town, Yuhang district, Hangzhou City, Zhejiang Province
Postal code, City	311107, Hangzhou
Country	China
Instrument	Electronic single-phase two-wire, energy meter Direct connected
Mark - Type	E3005-SA
Register	LCD
Accuracy Class	Active: B - 1000 imp./kWh
Measurement range	133/230 V – 230/400 V, 0,25..5(100) A , 0,5..10(100) A and 1,0..20(160) A, 60 Hz
Temperature range	-40 .. 75 °C
Use	Indoor
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).


Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3:2006	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)
Valid until	1 October 2030

Based on a non-recurrent examination.

Version 2 of this certificate. The results are recorded in the following annex: test report 1388-20 R0.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage
Laboratory

Arnhem, 1 October 2020