

## EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1344-17
Manufacturer	Hexing Electrical Co.,Ltd.
Contact person	Ms. Peggy Zheng
Address	1418-5, Moganshan Road, Shangcheng Industrial Zone, Hangzhou City,310011, Zhejiang Province
Country	China
Production site	Hexing Electrical Co.,Ltd.
Address	1418-5, Moganshan Road, Shangcheng industrial zone, Hangzhou City, 310011, Zhejiang Province
Country	China
Instrument	Electronic three-phase four-wire energy meter Direct connected
Mark - Type	HXE310
Register	LCD
Accuracy Class	Active: 1/B; Reactive: 2
Measurement range	230/400V, 0,25-5(80) or 0,25-5(100) A, 50 Hz Active: 1000 imp./kWh Reactive: 1000 imp./kvarh
Temperature range	-40 .. 70 °C
Use	Indoor, not sensitive to phase sequence
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).


Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006)	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006)	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)
Valid until	27 July 2027

Based on a non-recurrent examination.

Version 4 of this certificate. The results are recorded in the following annex: test report 1516-19 V5.

KEMA B.V.

  
Bas Verhoeven  
Director, High-Voltage  
Laboratory

 **Laboratories**

Arnhem, 30 March 2020

Copyright: Only integral reproduction of this Certificate is permitted without written permission from KEMA B.V.