

KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS


Manufacturer	Ningbo Sanxing Smart Electric Co., Ltd.
Contact person	Ms Jane Ye
Address	No.16 Fengwan Road, Cicheng Town
Postal code, City	Jiangbei District, Ningbo City, Zhejiang Province, 315034
Country	China
Production site	Ningbo Sanxing Smart Electric Co., Ltd.
Address	No.16 Fengwan Road, Cicheng Town
Postal code, City	Jiangbei District, Ningbo City, Zhejiang Province, 315034
Country	China
Instrument	Electronic three-phase four-wire energy meter. Direct connected
Mark - Type	P34S02, SX5A2-SELS-04, S34U18 and SX631
Register	LCD
Accuracy Class	Active: 1/B ; 1000 imp./kWh Reactive: 2 ; 1000 imp./kvarh
Measurement range	220/380 – 240/415 V, 50 Hz 0,25-5(100), 0,25-5(60), 0,5-10(60) and 0,5-10(100) A
Use	Indoor
Protection Class	II
Registry method	Bi-directional method separate registers: received- and delivered energy of the whole connection is added in separate registers

The energy meter meets the requirements of:
IEC 62052-11:2003, IEC 62053-21:2003 and IEC 62053-23:2003

Based on a non-recurrent examination.

The results are recorded in our test report with reference 1455-19 V3.

KEMA B.V.



Bas Verhoeven
Director, High-Voltage
Laboratory
Arnhem, 23 August 2019



KEMA

Laboratories