

## EU-TYPE EXAMINATION CERTIFICATE

Certificate number	1735-18
Manufacturer	Elster Solutions GmbH
Contact person	Mr Morar Bogdan
Address	Steinern Str. 19-21
Postal code, City	Mainz-Kastel
Country	Germany
Production site	Elster Solutions GmbH
Address	Steinern Str. 19-21
Postal code, City	Mainz-Kastel
Country	Germany
Instrument	Electronic single-phase two-wire, energy meter Direct connected
Mark - Type	HS330SH2LAT1
Register	LCD
Accuracy Class	Active: 1/B - 1000 imp./kWh Reactive: 2 - 1000 imp./kvarh
Measurement range	230 V, 0,25..5(60) A, 50 Hz
Temperature range	-40 .. 70 °C
Use	indoor
Protection Class	II
Environmental class	M1, E1 and E2
Registry method	Programmable, the meters are delivered as: Bi-directional method separate registers: received- and delivered energy is added in separate registers

The energy meters meet the requirements of Directive 2014/32/EU, on the harmonisation of the laws of Member States relating to the making available on the market of measuring instruments (recast).


Certification was based on compliance with the following harmonised standards:

EN 50470-1:2006	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3:2006	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)
Valid until	10 December 2028

Based on a non-recurrent examination.

Version 1 of this certificate. The results are recorded in the following annex: test report 1734-18 V1.

DNV GL Netherlands B.V.



Bas Verhoeven  
Director, High-Voltage  
Laboratory



Arnhem, 10 December 2018

Copyright: Only integral reproduction of this Certificate is permitted without written permission from DNV GL.