

CERTIFICATE

EC-Type examination certificate 6331-10

Manufacturer : Inepro Metering BV
Contact person : D. van der Vaart
Address : P.O. Box 92

Address : P.O. Box 92
Postal code, Place : 2450 AB, Leimuiden
Country : The Netherlands

Production site : Shanghai Fengyilong

Electronic Co., Ltd.

Address : Room 20D, Building 2, No. 1251,

Jiangning Road

Postal code, Place : Shanghai, 200060 Jiangsu, 213372

Country : China China

Instrument : Electronic single-phase two-wire energy meter

Direct connected

Mark - Type : KDK1-32AM-11

Register : Mechanical

Accuracy Class : B Measurement range : 230 V

5(45) A 50 Hz

2000 imp./kWh

Temperature range : -10..40 °C

Use : Indoor
Protection Class : II
Environmental class : M1, E2

Registry method : programmable

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test

conditions - Metering equipment (class indexes A, B and C)

Jiangsu Livang Electric

Xinchang Town, Liyang City

Instrument Co., Ltd.

EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for

active energy (class indexes A, B and C)

Valid until : March 30, 2020

The results are recorded in the following annex: test report 2113897-TDT 6331-10.

KEMA Quality B.V.

Arnhem, April 22, 2010

ir. A.P.M. Baars Certification manager Notified body number 0344 ir. P.J.J.G. Nabuurs
Managing Director

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed. This certificate is issued provided that neither KEMA nor the RvA assumes any liability.