

CERTIFICATE

TYPE TEST OF ENERGY METERS

Manufacturer : Inepro Metering BV
Contact person : D. van der Vaart
Address : P.O. Box 92
Postal code, Place : 2450 AB, Leimuiden
Country : The Netherlands

Production site : Shanghai Fengyilong Electronic Co., Ltd. Jiangsu Liyang Electric Instrument Co., Ltd.
Address : Room 20D, Building 2, No. 1251, Jiangning Road Xinchang Town, Liyang City
Postal code, Place : Shanghai, 200060 Jiangsu, 213372
Country : China China

Instrument : Electronic single-phase two-wire energy meter
Direct connected
Type : Autometers D-300
Register : LCD
Accuracy Class : 1 / B
Measurement range : 230 V
10(100) A
50 or 60 Hz
: 1600 imp./kWh
Use : Indoor
Protection Class : II


The energy meter meets the requirements of:


- IEC 62052-11 (2003) : Electricity metering equipment (a.c.) - General requirements, tests and test conditions - Metering equipment
IEC 62053-21 (2003) : Electricity metering equipment (a.c.) - Static meters for active energy (classes 1 and 2)

Based on a non-recurrent examination.

The results are recorded in our test report with reference 70965037-TDT 6332-10.

KEMA Quality B.V.
Arnhem, April 22, 2010


ir. A.P.M. Baars
Certification manager


ir. P.J.J.G. Nabuurs
Managing Director
Certificate nr. 70965037-TDT 6332-10C

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.