

# CERTIFICATE

## EC-Type examination certificate 6335-10

Manufacturer	:	Inepro Metering BV		
Contact person	:	D. van der Vaart		
Address	:	P.O. Box 92		
	:	2450 AB, Leimuiden		
Country	:	The Netherlands		
Production site	:	Shanghai Fengyilong	Jiangsu Linyang Electric	
	:	Electronic Co., Ltd.	Instrument Co., Ltd.	
Address	:	Room 20D, Building 2, No. 1251,	Xinchang Town, Liyang City	
	:	Jiangning Road		
Postal code, Place	:	Shanghai, 200060	Jiangsu, 213372	
Country	:	China	China	
Instrument	:	Electronic single-phase two-wire energy meter Direct connected		
Mark - Type	:	PRO-75A	PRO-75D	PRO-75D MODBUS
Register	:	Mechanical	LCD	LCD
Accuracy Class	:	1 / B		
Measurement range	:	230 V		
	:	10(100) A		
	:	50 or 60 Hz		
	:	1600 imp./kWh		
Temperature range	:	-10..40 °C		
Use	:	Indoor		
Protection Class	:	II		
Environmental class	:	M1, E2		
Registry method	:	bidirectional method with always positive register: the meter always counts the energy of the measuring point as received energy, irrespective of the real energy direction.		

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:


EN 50470-1 (2006)	:	Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
EN 50470-3 (2006)	:	Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : June 11, 2020

The results are recorded in the following annex: test report 70965037-TDT 6335-10.

KEMA Quality B.V.  
Arnhem, June 11, 2010

ir. A.P.M. Baars  
Certification manager  
Notified body number 0344



ir. P.J.J.G. Nabuurs  
Managing Director

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.  
This certificate is issued provided that KEMA not assumes any liability.