



CERTIFICATE

EC-Type examination certificate 6989-12

Manufacturer	: Inepro Metering BV	
Contact person	: D. van der Vaart	
Address	: P.O. Box 92	
Postal code, Place	: 2450 AB, Leimuiden	
Country	: The Netherlands	
Production site	: Shanghai Fengyilong Electronic Co., Ltd.	Shanghai Fengyilong Electronic Co., Ltd.
Address	: Room 20D, Building 2, No. 1251, Jiangning Road	Room 20D, Building 2, No. 1251, Jiangning Road
Postal code, Place	: Shanghai, 200060	Shanghai, 200060
Country	: China	China
Instrument	: Electronic three-phase four-wire energy meter Direct connected	
Mark - Type	: PRO1250A	
Register	: Mechanical	
Accuracy Class	: 1 / B	
Measurement range	: 230/400 V 10(100) A 50 or 60 Hz 320 imp./kWh	
Temperature range	: -25..55 °C	
Use	: Indoor	
Protection Class	: II	
Environmental class	: M1, E2	
Registry method	: The meter is suitable for energy registration in one direction only and must be marked as such on the typeplate.	

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

- EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
- EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : July 19, 2022

Based on a non-recurrent examination.

The results are recorded in the following annex: test report 70068237-TIC 6989-12.

KEMA Nederland B.V. - Calibration & Metering
Arnhem, July 19, 2012

ir. A.P.M. Baars
Certification manager
Notified body number 2290

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.

KEMA Nederland B.V. Utrechtseweg 310, 6812 AR Arnhem, The Netherlands P.O. Box 9035, 6800 ET Arnhem, The Netherlands
T +31 (0)26 3 56 2215 F +31 (0)26 4 42 6211 C&M@kema.com www.kema.com trade register Arnhem 09080262

ing. S.A.M. Verhoeven
Director Testing, Inspections & Certification