



CERTIFICATE

EC-Type examination certificate 6990-11

Manufacturer	: Inepro Metering BV		
Contact person	: D. van der Vaart		
Address	: P.O. Box 92		
Postal code, Place	: 2450 AB, Leimuiden		
Country	: The Netherlands		
Production site	: Shanghai Fengyilong Electronic Co., Ltd.	Jiangsu Linyang Electric Instrument Co., Ltd.	
Address	: Room 20D, Building 2, No. 1251, Jiangning Road	Xinchang Town, Liyang City	
Postal code, Place	: Shanghai, 200060	Jiangsu, 213372	
Country	: China	China	
Instrument	: Electronic three-phase four-wire energy meter Transformer connected		
Mark - Type	: PRO1250D CT	PRO1250D CT MODBUS	PRO1250D CT MBUS
Register	: LCD		
Accuracy Class	: 1 / B		
Measurement range	: 230/400 V 1,5(6) A 50 or 60 Hz 1600 imp./kWh		
Temperature range	: -25..55 °C		
Use	: Indoor		
Protection Class	: II		
Environmental class	: M1, E2		
Registry method	: The meter is suitable for energy registration in one direction only.		

The energy meter meets the requirements of Directive 2004/22/EC of the European parliament and the council of 31 March 2004 on measuring instruments.

Certification was based on compliance with the following harmonised standards:

- EN 50470-1 (2006) : Electricity metering equipment (a.c.)-part 1: General requirements, tests and test conditions - Metering equipment (class indexes A, B and C)
- EN 50470-3 (2006) : Electricity metering equipment (a.c.)-part 3: Particular requirements - Static meters for active energy (class indexes A, B and C)

Valid until : August 15, 2021

The results are recorded in the following annex: test report 72140347-TIC 6990-11.

KEMA T&D Testing Services - Calibration and Metering
Arnhem, August 15, 2011

ir. A.P.M. Baars
Certification manager
Notified body number 2290


ing. S.A.M. Verhoeven
Director Testing, Inspections & Certification

The investigation reported here does not confer any right to use an approbation mark granted by KEMA.

Integral publication of this certificate and adjoining reports is allowed.
This certificate is issued provided that neither KEMA nor the RvA assumes any liability.