

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis+Gyr AG Theilerstrasse 1 CH 6301 Zug Switzerland
Measuring instrument	A static Active Electrical Energy Meter Type : ZMF1x0AC or ZFF1x0AC : ZMF1x0AB or ZFF1x0AB Manufacturer's mark or name : Landis+Gyr Reference voltage : 3x230/400 V (ZMF) or 3x230V (ZFF) Reference current : 5, 10 or 20 A Destined for the measurement of : electrical energy, in a : - three-phase four-wire network : - three-phase three-wire network : - two-phase three-wire network : - single-phase two-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: – Description T10031 revision 6; – Documentation folder T10031-4.
Valid until	15 January 2027
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
 15 January 2017



C. Oosterman
 Head Certification Board

NMi Certin B.V.
 Hugo de Grootplein 1
 3314 EG Dordrecht
 The Netherlands
 T +31 78 6332332
 certin@nmi.nl
 www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.