


Issued by	NM Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis+Gyr AG Theilerstrasse 1 CH 6301 Zug Switzerland
Measuring instrument	A static Active Electrical Energy Meter
	Type : (E650) ZMD/ZFD300/400... (S650) SMA/SFA300/400...
	Manufacturer's mark or name : Landis+Gyr AG
	Reference voltage : ZMD/SMA300: 3x220/380V...3x240/415V ZMD/SMA400: 3x57,7/100V...3x240/415V ZFD/SFA400: 3x100V...3x415V
	Reference current : ZMD/SMA300: 5, 10, 15 or 20 A ZMD/ZFD/SMA/SFA400: 0,3, 1, 2 or 5 A
	Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network - two-phase three-wire network - single-phase two-wire network
	Accuracy class : ZMD/SMA300: A or B ZMD/ZFD/SMA/SFA 400: B or C
	Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C
	Further properties are described in the annexes: - Description T10033 revision 12; - Documentation folder T10033-10.

Valid until 31 January 2027

Remarks This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NM Certin B.V., Notified Body number 0122**
 31 January 2017



C. Oosterman
 Head Certification Board

NM Certin B.V.
 Hugo de Grootplein 1
 3314 EG Dordrecht
 The Netherlands
 T +31 78 6332332
 certin@nmi.nl
 www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NM Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.