

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer SAGEMCOM ENERGY & TELECOM SAS
250 route de l'Empereur
92848 RUEIL MALMAISON CEDEX
France

Measuring instrument A static **Active Electrical Energy Meter**

Type	: CX1000-3
Reference voltage	: 230 V
Reference current	: 5 or 10 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: A or B
Environment classes	: M1 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:
- Description T10043 revision 19;
- Documentation folder T10043-14.

Valid until 21 December 2026

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
27 August 2019


C. Oosterman
Head Certification Board