

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 9 of Directive 2004/22/EC, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2004/22/EC, to:

Manufacturer Kamstrup A/S
Industrivej 28, Stilling
DK-8660 Skanderborg
Denmark

Measuring instrument A static **Active Electrical Energy Meter**

Type : 684-...
(Kamstrup 382B/C/D/E/G/H/J/K/L or 282K/L)

Reference voltage : 3 x 230/400V or 3 x 230V
Reference current : 5 or 10 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B
Environment classes : M2 / E2
Temperature range : -40 °C / +70 °C

Further properties are described in the annexes
– Description T10063 revision 36
– Documentation folder T10063-11

Valid until 23 March 2017

Remarks This revision replaces the earlier versions, except for its documentation
folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
19 September 2012

C. Oosterman
Head Certification Board