

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	SAGEMCOM ENERGY & TELECOM SAS 250 route de l'Empereur 92848 RUEIL MALMAISON CEDEX France
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : CX1000-5 (X15) Reference voltage : 230 V Reference current : 5 or 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - two-phase three-wire network - single-phase two-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10081 revision 4 - Documentation folder T10081-3
Valid until	13 September 2017
Remarks	This revision replaces the earlier version(s), except for its documentation folder.
Issuing Authority	<b>NMi Certin B.V., Notified Body number 0122</b> 14 February 2013

C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete document only is permitted.