

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Itron 1 Avenue des temps modernes ZI du Bernais B.P. 23 86361 Chasseneuil du Poitou France
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : SL761B / SL761E / SL760 Reference voltage : 3x57,7/100 .... 3x240/415 V Reference current : SL761B or SL760 transformer connected (TC): 1; 1,5; 2,5 or 5A SL761E or SL760 direct connected (DC): 5; 10; 15 or 20A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network Accuracy class : SL761B or SL760 (TC): B or C SL761E or SL760 (DC): A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C  Further properties are described in the annexes: - Description T10090 revision 11; - Documentation folder T10090-3.
Valid until	24 September 2017
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
18 March 2016

  
C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
manufacturer shall indemnify third-party  
liability.

The designation of NMi Certin BV.as Notified  
Body can be verified at [http://  
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge  
objection against this decision,  
within six weeks after the date of  
submission, to the general manager  
of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete  
document only is permitted.