

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Kamstrup A/S Industrivej 28, Stilling DK-8660 Skanderborg Denmark
Measuring instrument	A static Active Electrical Energy Meter Type : 686-... (Kamstrup 162B/C/D/E/J/K/L) Reference voltage : 230 V Reference current : 5A or 10A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10097 revision 26 - Documentation folder T10097-8
Valid until	13 August 2017
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
19 September 2012

C. Oosterman
Head Certification Board