

Issued by NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands

In accordance with The "Metrologiewet" (Stb. 2006, 137) as Dutch implementation of Directive 2004/22/EC on measuring instruments (MID).

Manufacturer Landis+Gyr S.p.A.
Via del Maggiolino, 53/57
00155 Roma
Italy

In respect of A model of a static **Active Electrical Energy Meter**

Type : LENNT-S1A, LENTT-S1A-M or LENNT-S3A

Characteristics Reference voltage : 230 V
Reference current : 5 A
Destined for the measurement of : electrical energy, in a
- single-phase two-wire network
Accuracy class : C
Mechanical environment class : M2
Electromagnetic environment class : E2
Temperature range : -40°C / +70°C

In the description number T10127 revision 1 further characteristics are described.

Valid until 14 March 2018

Description and documentation The instrument is described in the description number T10127 revision 1 and documented in the documentation folder T10127-1, appertaining to this EC-type examination certificate.

Remark This revision replaces the previous version, except for its documentation folder.

Notified Body number 0122
NMI Certin, 10 June 2009

Ing. C. Oosterman
Head Certification Board