

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	SAGEMCOM ENERGY & TELECOM SAS 250 route de l'Empereur 92848 RUEIL MALMAISON CEDEX France
Measuring instrument	A static Active Electrical Energy Meter Type : CX2000-5 CLK RS232 Reference voltage : 3x230/400 V Reference current : 5 or 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes – Description T10129 revision 2 – Documentation folder T10129-1
Valid until	13 May 2018
Remarks	This revision replaces the earlier version(s), except for its documentation folder.
Issuing Authority	NMi Certin B.V., Notified Body number 0122 14 February 2013

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.