

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	EMH Elektrizitätszähler GmbH & Co KG Südring 5 D-19243 Wittenburg Germany
Measuring instrument	<b>A static Active Electrical Energy Meter</b> Type : ITZ-P as direct connected (DCM) and transformer connected (TCM) meter Reference voltage : 3x220/380V...3x240/415V Reference current : 1 A (TCM) 5 or 10 A (DCM) Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : B (TCM) B or A (DCM) Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C  Further properties are described in the annexes - Description T10161 revision 2 - Documentation folder T10161-1
Valid until	9 January 2019
Remarks	This revision replaces the earlier version(s), except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
30 November 2009

  
C. Oosterman  
Head Certification Board