

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr
1 Lysander Drive, Northfields Industrial Estate
Market Deeping, Peterborough, PE6 8FB
England

Measuring instrument A static **Active Electrical Energy Meter**
Type : (E350s2 polyphase)
ZFF1.....s2 or ZMF1.....s2

Manufacturer's mark or name : Landys + Gyr

Reference voltage : ZMF1: 3x110/190 V..3x240/415 V (B2)
ZFF1: 3x230/ V (B2)
ZMF1: 3x230/400 V (SMR5)

Reference current : 5, 10, 15 or 20 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network
- two-phase three-wire network
- single-phase two-wire network

Accuracy class : A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10163 revision 29;
- Documentation folder T10163-14.

Valid until 21 October 2028

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
21 June 2019


C. Oosterman
Head Certification Board