



Nederlands Meetinstituut

EC-type examination certificate

Number **T10189** revision 0
Project number 806920
Page 1 of 1

Issued by NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands

Notified Body number 0122

In accordance with The "Metrologiewet" (Stb. 2006, 137) as Dutch implementation of Directive 2004/22/EC on measuring instruments (MID).

Manufacture LUMEL Spółka Akcyjna
ul. Sulechowska 1
65-022 Zielona Góra
Poland

In respect of A model of a static **Active Electrical Energy Meter**

Type : EM03

Characteristics Reference voltage : 3 x 127/220 V or 3 x 230/400 V
Reference current : 5 or 10 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : A or B
Mechanical environment class : M1
Electromagnetic environment class : E2
Temperature range : -40°C / +70°C

In the description number T10189 revision 0 further characteristics are described.

Valid until 2 February 2019

Description and documentation The instrument is described in the description number T10189 revision 0 and documented in the documentation folder T10189-1, appertaining to this EC-type examination certificate.

Dordrecht, 2 February 2009
NMI Certin B.V.

Ing. C. Oosterman
Manager Product Certification

NMI Certin BV
Hugo de Grootplein 1
3314 EG Dordrecht
PO Box 394
3300 AJ Dordrecht, NL
T +31 78 6332332
F +31 78 6332309
certin@nmi.nl
www.nmi.nl

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMI (see "Regulation objection and appeal against decisions of NMI")

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

Reproduction of the complete document is permitted.

