

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument A static **Active Electrical Energy Meter**

Type	: 835x1-3xxxx
Reference voltage	: 3x230/400 V
Reference current	: 5 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network
Accuracy class	: B or C
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10228 revision 11;
- Documentation folder T10228-2.

Valid until 18 May 2030

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
18 May 2020

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.