

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to  
conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
having established that the Measuring instrument meets the applicable  
requirements of Directive 2014/32/EU, to:

Manufacturer BTicino SpA  
Viale Borri, 231  
21100 - Varese (VE)  
Italy

Measuring instrument A static **Active Electrical Energy Meter**  
Type : CE4DMID0x  
Manufacturer's mark or name : IME, LGR, SCH, btc, SRK, MLR, NHP,  
HGR, SMS, LAB or SIE  
Reference voltage : 3x57,7/100...3x277/480V (3p4w)  
3x100...3x480 V (3p3w)  
Reference current : 5 A  
Destined for the measurement of : electrical energy, in a  
- three-phase four-wire network  
- two-phase three-wire network  
- single-phase two-wire network  
Accuracy class : A or B  
Environment classes : M1 / E2  
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:  
- Description T10240 revision 7;  
- Documentation folder T10240-5.

Valid until 15 January 2030

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
15 January 2020

Certification Board