

Issued by NMI Certin B.V.,  
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Landis+Gyr  
1 Lysander Drive, Northfields Industrial Estate  
Market Deeping, Peterborough PE6 8FB  
England

Measuring instrument A static **Active Electrical Energy Meter**  
Type : E350s2 single phase (5271)  
Type ZCF1....s2

Manufacturer's mark or name : Landis + Gyr

Reference voltage : 230 V and 127 V (B2)  
230 V (SMR5)

Reference current : 5, 10, 15 or 20 A (B2)  
5, 10 or 15 A (SMR5)

Destined for the measurement of : electrical energy, in a  
- single-phase two-wire network

Accuracy class : A or B (B2)  
A (SMR5)

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10244 revision 28;
- Documentation folder T10244-11.

Valid until 15 October 2029

Remark This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
4 June 2020

## Certification Board

**NMI Certin B.V.**  
Thijsseweg 11  
2629 JA Delft  
The Netherlands  
T +31 88 636 2332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.