

# EC type-examination Certificate

Number **T10317** revision 7  
Project number 15200664  
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	SAGEMCOM ENERGY & TELECOM SAS 250 route de l'Empereur 92848 RUEIL MALMAISON CEDEX France
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : C3500 Reference voltage : 3x230/400 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : B or C Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C  Further properties are described in the annexes: - Description T10317 revision 7; - Documentation folder T10317-1.
Valid until	30 November 2020
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
27 October 2015

  
C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete document only is permitted.