


# EC type-examination Certificate

Number **T10321** revision 9  
Project number SO14200164  
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Dr. Neuhaus Telekommunikation GmbH Papenreye 65 D-22453 Hamburg Germany
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : SMARTY ix-130 Reference voltage : 3 x 230/400 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - one-phase two-wire network Accuracy class : A Environment classes : M2 / E2 Temperature range : -25 °C / +55 °C  Further properties are described in the annexes: - Description T10321 revision 9; - Documentation folder T10321-2.
Valid until	12 November 2020
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
23 January 2014



C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge  
objection against this decision,  
within six weeks after the date of  
submission, to the general manager  
of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete  
document only is permitted.