

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis+Gyr 1 Lysander Drive, Northfields Industrial Estate, Market Deeping, Peterborough, PE6 8FB England
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : (E450) ZMX310G and ZMX320G Manufacturer's mark or name : Landis + Gyr Reference voltage : 3x230/400 V Reference current : 5 A or 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - two-phase three-wire network - single-phase two-wire network - three-phase three-wire network Accuracy class : A (ZMX320) or B (ZMX310) Environment classes : M2 / E2 Temperature range : -40 °C / +55 °C Further properties are described in the annexes - Description T10336 revision 4 - Documentation folder T10336-5
Valid until	18 February 2021
Remark	This revision replaces the earlier version, including its documentation folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**  
4 January 2017



C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.