

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Switch Energy Global Pty Ltd. Suite 305, Al Futtaim Tower, Al Maktoum Street, Deira, Dubai United Arab Emirates
Measuring instrument	A static Active Electrical Energy Meter Type : MM3P xx (SX5A2-SELS-04) Reference voltage : 3*230/400 V (MM3P and MM3P CT) 3*57,7/100 V (MM3P CTVT) Reference current : 10 A (MM3P DC) 1,5 A (MM3P CT and MM3P CTVT) Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : B (MM3P) or C (MM3P CT and MM3P CTVT) Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10412 revision 0 - Documentation folder T10412-1
Valid until	22 February 2022

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
22 February 2012


C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.