

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Ningbo Sanxing Electric Co., Ltd. No. 1166, Mingguang North Road, Jiangshan Town, Ningbo China
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : SX5A2-SELS-04 Reference voltage : 3*230/400 V (DC and CT version) 3*57,7/100 V (CTVT version) Reference current : 10 A (DC version) 1,5 A (CT and CTVT version) Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : B (DC version) or C (CT and CTVT version) Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10414 revision 0 - Documentation folder T10414-1
Valid until	22 February 2022

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
22 February 2012

  
C. Oosterman  
Head Certification Board