

Issued by NMI Certin B.V.,  
 designated and notified by the Netherlands to perform tasks with respect to  
 conformity modules mentioned in article 17 of Directive 2014/32/EU, after  
 having established that the Measuring instrument meets the applicable  
 requirements of Directive 2014/32/EU, to:

Manufacturer Elster Rometrics SRL  
 Timisoara Airport Park  
 DJ691 km8+775m  
 307210 Giarmata  
 Romania

Measuring instrument A static **Active Electrical Energy Meter**

- Type : AS3000(V) or AS3500(V) or AS3000DTC or AS3500DTC
- Manufacturer's mark or name : Elster or Honeywell
- Reference voltage : 3x230/400 or 3x230V (AS3000(V) DC and CT)  
 3x240/415V or 3x240V (AS3000(V) DC and CT)  
 3x58/100V or 3x100V (AS3500(V) CT)  
 3x63/110V or 3x110V (AS3500(V) CT)  
 3x230/400V or 3x230V (AS3500(V) CT)  
 3x240/415V or 3x240V (AS3500(V) CT)  
 3x230/400 or 3x230V (AS3000DTC DC and CT)  
 3x240/415V or 3x240V (AS3000DTC DC and CT)  
 3x240/415V (AS3500DTC DC and CT)  
 3x58/100V or 3x100V (AS3500DTC CT)  
 3x63/110V or 3x110V (AS3500DTC CT)
- Reference current : 5, 10 or 20 A (AS3000(V) DC)  
 1, 5 or 10 A (AS3500(V) CT)  
 5 A (AS3000DTC DC)  
 5 or 1 A (AS3000DTC CT)
- Destined for the measurement of : electrical energy, in a  
 - three-phase four-wire network  
 - three-phase three-wire network  
 - two-phase three-wire network  
 - single-phase two-wire network
- Accuracy class : A or B (AS3000 and AS3000DTC)  
 B or C (AS3500 and AS3500DTC)
- Environment classes : M2 / E2
- Temperature range : -40 °C / +70 °C