

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer Networked Energy Services
5215 Hellyer Avenue, Suite 150
San Jose, CA 95138
United States of America

Measuring instrument A static **Active Electrical Energy Meter**

Type	: 835x2-3xxxx
Reference voltage	: 3x220/380 V ... 3x240/415 V
Reference current	: 1 A or 5 A
Destined for the measurement of	: electrical energy, in a - three-phase four-wire network
Accuracy class	: B or C
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10472 revision 10;
- Documentation folder T10472-3.

Valid until 26 June 2022

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
12 March 2019


C. Oosterman
Head Certification Board