

EC type-examination Certificate

Number **T10531** revision 1
Project number 12200792
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Itron, Inc. 313 North Highway 11 West Union, SC 29696 United States of America
Measuring instrument	A static Active Electrical Energy Meter Type : C2BOD Reference voltage : 220V or 230V Reference current : 15 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes - Description T10531 revision 1 - Documentation folder T10531-1
Valid until	13 March 2023
Issuing Authority	NMi Certin B.V., Notified Body number 0122 26 March 2013

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMi (see www.nmi.nl).

Reproduction of the complete document only is permitted.