

EC type-examination Certificate

Number **T10540** revision 0
Project number SO12201636
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	Legrand Group 128 Avenue De Lattre De Tassigny 87045 Limoges Cedex France
Measuring instrument	A static Active Electrical Energy Meter Brand : Legrand Type : 04685 or 04686 Reference voltage : 3x57,7/100...3x277/480V (3p4w) 3x100...3x480 V (3p3w) Reference current : 5 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network - three-phase three-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -25 °C / +55 °C Further properties are described in the annexes – Description T10540 revision 0 – Documentation folder T10540-1
Valid until	15 February 2023

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
15 February 2013

C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.