

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	EMH metering GmbH & Co. KG Neu-Galliner Weg 1 D-19258 Gallin Germany
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : NXT4 as direct connected meter (DCM) and transformer connected meter (TCM) Manufacturer's mark or name : EMH metering Reference voltage : 3x220/380V, 3x230/400V, 3x240/415V (DCM/TCM) 3x58/100V, 3x63/110V (TCM) 3x277/480V (TCM) Reference current : 5 A (DCM) 1 A or 5 A (TCM) Destined for the measurement of : electrical energy, in a - three-phase four-wire network - two-phase three-wire network (DCM) - one-phase two-wire network (DCM) Accuracy class : A or B (DCM) B or C (TCM) Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: - Description T10592 revision 14; - Documentation folder T10592-6.
Valid until	8 October 2023
Remark	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority

**NMi Certin B.V., Notified Body number 0122**

27 February 2017

  
C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/enterprise/newapproach/nando/>

Reproduction of the complete document only is permitted.