

3631 Issued by

NMi Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:

Manufacturer

Itron
1 Avenue des temps modernes
ZI du Bernais B.P. 23
86361 Chasseneuil du Poitou
France

Measuring instrument

A static **Active Electrical Energy Meter**

Type : ITE414L1B
Reference voltage : 3x230/400 V
Reference current : 10 A
Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
Accuracy class : A or B
Environment classes : M1 / E2
Temperature range : -25 °C / +55 °C

Further properties are described in the annexes:

- Description T10626 revision 7;
- Documentation folder T10626-6.

Valid until

30 April 2025

Remark

This revision replaces the earlier versions, excluding its documentation folder.

Issuing Authority

NMi Certin B.V., Notified Body number 0122
12 July 2021

Certification Board