

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of module B of Directive 2004/22/EC, to:
Manufacturer	GE Energy Management - Industrial Solutions Nieuwevaart 51 9000 Gent Belgium
Measuring instrument	A static Active Electrical Energy Meter Brands : GE Type : MT+D3N485 63 4M MID or MT+D3Ni 63 4M MID Reference voltage : 3x190/328...3x277/480 V Reference current : 10 A Destined for the measurement of : electrical energy, in a - three-phase four-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -25 °C / +55 °C Further properties are described in the annexes: - Description T10640 revision 0; - Documentation folder T10640-1.
Valid until	4 July 2024

Issuing Authority

NMi Certin B.V., Notified Body number 0122
4 July 2014



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision
that no liability is accepted and that the
applicant shall indemnify third-party liability.

The designation of NMi Certin BV.as Notified
Body can be verified at [http://
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge
objection against this decision,
within six weeks after the date of
submission, to the general manager
of NMi (see www.nmi.nl).

Reproduction of the complete
document only is permitted.