

Issued by	NMI Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Landis+Gyr AG Theilerstrasse 1 CH 6301 Zug Switzerland
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : (E570) ZMY400 / ZFY400 Manufacturer's mark or name : Landis + Gyr Reference voltage : ZMY400: 3x220/380 V - 240/415 V ZFY400: 3x220 V – 3x240 V Reference current : 1 A, 2 A or 5 A Reference frequency : 50 Hz Destined for the measurement of : electrical energy, in a ZMY400: - three-phase four-wire network - two-phase three-wire network - single-phase two-wire network ZFY400: - three-phase three-wire network Accuracy class : B or C Environment classes : M2 / E2 Temperature range : -40 °C / +70 °C Further properties are described in the annexes: – Description T10674 revision 2; – Documentation folder T10674-2.
Valid until	20 March 2025
Remark	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**  
25 January 2017



C. Oosterman  
Head Certification Board