

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Landis + Gyr UK Ltd.
1 Lysander Drive, Northfields Ind Est
PE6 8FB Peterborough
United Kingdom

Measuring instrument A static **Active Electrical Energy Meter**

Type	: E450 G3 IDIS (ZCXi1x0xQ S4)
Reference voltage	: 230 V
Reference current	: 5 A or 10 A
Destined for the measurement of	: electrical energy, in a - single-phase two-wire network
Accuracy class	: B or A
Environment classes	: M2 / E2
Temperature range	: -40 °C / +70 °C

Further properties are described in the annexes:

- Description T10689 revision 12;
- Documentation folder T10689-5.

Valid until 12 June 2025

Remarks This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMI Certin B.V., Notified Body number 0122**
22 October 2020

Certification Board

NMI Certin B.V.
Thijsseweg 11
2629 JA Delft
The Netherlands
T +31 88 636 2332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMI Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.

This document is digitally signed and sealed. The digital signature can be verified in the blue ribbon at the top of the electronic version of this certificate.