


Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Qingdao iTechene Technologies Co., Ltd No. 169 Songling Road, Laoshan District 266061 Qingdao China
Measuring instrument	A static Active Electrical Energy Meter Type : TCE-MT-1000S or TA75 Reference voltage : 230 V Reference current : 10 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Location : Indoor Further properties are described in the annexes: - Description T10700 revision 3; - Documentation folder T10700-3.
Valid until	5 November 2025
Remark	This revision replaces the earlier versions, including its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**
3 April 2018



C. Oosterman
Head Certification Board

NMi Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
T +31 78 6332332
certin@nmi.nl
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.