

Issued by NMI Certin B.V.,
designated and notified by the Netherlands to perform tasks with respect to
conformity modules mentioned in article 17 of Directive 2014/32/EU, after
having established that the Measuring instrument meets the applicable
requirements of Directive 2014/32/EU, to:

Manufacturer Itron Indonesia - PT Mecoindo
EJIP Plot 6B-2, Lemah Abang
17550 Bekasi, Jawa Barat
Indonesia

Measuring instrument **A static Active Electrical Energy Meter**

Type : ACE661B / ACE661D and
ACE662B / ACE662D

Manufacturer's mark or name : Itron

Reference voltage : 3x57,7/100 V 3x240/415 V

Reference current : ACE66.B: 1; 1,5; 2,5 or 5 A
ACE66.D: 5; 10; 15 or 20 A

Destined for the measurement of : electrical energy, in a
- three-phase four-wire network
- three-phase three-wire network

Accuracy class : ACE66.B: B or C
ACE66.D: A or B

Environment classes : M2 / E2

Temperature range : -40 °C / +70 °C

Further properties are described in the annexes:
– Description T10709 revision 5;
– Documentation folder T10709-4.

Valid until 3 July 2025

Remark This revision replaces the earlier versions, including its documentation folder.

Issuing Authority

NMI Certin B.V., Notified Body number 0122
12 May 2021

Certification Board