

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity assessment procedures mentioned in article 17 of Directive 2014/32/EU, after having established that the Measuring instrument meets the applicable requirements of Directive 2014/32/EU, to:
Manufacturer	Elster Solutions GmbH Steinern Strasse 19-21 55252 Mainz-Kastel Germany
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : AS2020 Manufacturer's mark or name : Elster or Honeywell Reference voltage : 3x230/400 V 230 V Reference current : 5 A or 10 A (DC) 1 A (CT) Destined for the measurement of : electrical energy, in a - three-phase four-wire network - single-phase two-wire network Accuracy class : A or B Environment classes : M1 / E2 Temperature range : -40 °C / +70 °C Protection class : IP54  Further properties are described in the annexes: - Description T10711 revision 4; - Documentation folder T10711-2.
Valid until	20 December 2026
Remarks	This revision replaces the earlier versions, except for its documentation folder.

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
26 June 2018



C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision that no liability is accepted and that the manufacturer shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified Body can be verified at <http://ec.europa.eu/growth/tools-databases/nando/>

Reproduction of the complete document only is permitted.